



The **Houston Fire Code** and **NFPA 14** permit the removal of fire hose cabinet under the following conditions:

- The building is **100% protected throughout** with an automatic sprinkler system.
- **Class I standpipe hose connections** are provided in accordance with **Section 905 of the Houston Fire Code** and **NFPA 14**,
- A letter from a licensed Fire protection Service Company stating, “The building in question meets the requirement of **NFPA 14** and **IFC section 905** for travel distance and coverage.”
- **Prior approval** from the Fire Marshal’s Office has been obtained.

• Building Management: \_\_\_\_\_

• Inspector: \_\_\_\_\_

• Sr. Inspector: \_\_\_\_\_

• Chief Inspector: \_\_\_\_\_